

Bid Document

Bid Details	
Bid End Date/Time	22-02-2022 18:00:00
Bid Opening Date/Time	22-02-2022 18:30:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	60 (Days)
Ministry/State Name	Ministry Of Chemicals And Fertilizers
Department Name	Department Of Chemicals And Petrochemicals
Organisation Name	Brahmaputra Cracker And Polymer Limited (bcpl) Guwahati Assam
Office Name	Lepetkata
Total Quantity	819
Item Category	Porcelain insulators for overhead power lines with a nominal voltage Greater than 1000 V as per IS: 731 (Q3)
MSE Exemption for Years of Experience and Turnover	No
Startup Exemption for Years of Experience and Turnover	No
Document required from seller	Additional Doc 1 (Requested in ATC), Additional Doc 2 (Requested in ATC) *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
Bid to RA enabled	No
Primary product category	Porcelain insulators for overhead power lines with a nominal voltage Greater than 1000 V as per IS: 731
Time allowed for Technical Clarifications during technical evaluation	5 Days
Evaluation Method	Item wise evaluation

EMD Detail

Advisory Bank	ICICI
EMD Percentage(%)	2.00

ePBG Detail

Advisory Bank	ICICI
---------------	-------

ePBG Percentage(%)	3.00
Duration of ePBG required (Months).	6

(a). EMD EXEMPTION: The bidder seeking EMD exemption, must submit the valid supporting document for the relevant category as per GeM GTC with the bid. Under MSE category, only manufacturers for goods and Service Providers for Services are eligible for exemption from EMD. Traders are excluded from the purview of this Policy.

(b). The EMD % will be applicable for each schedule/group selected during Bid creation.

(c). EMD & Performance security should be in favour of Beneficiary, wherever it is applicable.

Beneficiary:

Senior Manager

Lepetkata, Department of Chemicals and Petrochemicals, Brahmaputra Cracker and Polymer Limited (BCPL)

Guwahati Assam, Ministry of Chemicals and Fertilizers

(Mausoom Choudhury)

Splitting

Bid splitting not applied.

MII Purchase Preference

MII Purchase Preference	No
-------------------------	----

Details of the Competent Authority for MII

Name of Competent Authority	Pranjal Phukan
Designation of Competent Authority	Chief Manager
Office / Department / Division of Competent Authority	Contracts & Procurement Deptt
CA Approval Number	LE21033
Competent Authority Approval Date	01-02-2022
Brief Description of the Approval Granted by Competent Authority	Make in india not applicable PROCUREMENT OF SPARE POLYMERIC PIN,DISC, POST AND GOAB INSULATOR FOR 33KV OH LINE The delivery shall be made within 90 days from the date of issue of award (LOI/PO). Estimate Rs 8,10,100/- [inclusive of GST]

Competent Authority Approval for not opting Make In India Preference : [View Document](#)

MSE Purchase Preference

MSE Purchase Preference	Yes
-------------------------	-----

1. Purchase preference to Micro and Small Enterprises (MSEs): Purchase preference will be given to MSEs as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail the Purchase preference, the bidder must be the manufacturer of the offered

product in case of bid for supply of goods. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service. If L-1 is not an MSE and MSE Seller (s) has/have quoted price within L-1+ 15% (Selected by Buyer) of margin of purchase preference /price band defined in relevant policy, such Seller shall be given opportunity to match L-1 price and contract will be awarded for 25%(selected by Buyer) percentage of total QUANTITY.

2. Estimated Bid Value indicated above is being declared solely for the purpose of guidance on EMD amount and for determining the Eligibility Criteria related to Turn Over, Past Performance and Project / Past Experience etc. This has no relevance or bearing on the price to be quoted by the bidders and is also not going to have any impact on bid participation. Also this is not going to be used as a criteria in determining reasonableness of quoted prices which would be determined by the buyer based on its own assessment of reasonableness and based on competitive prices received in Bid / RA process.

Evaluation Method (Item Wise Evaluation Method)

Contract will be awarded schedulewise and the determination of L1 will be done separately for each schedule. The details of item-consignee combination covered under each schedule are as under:

Evaluation Schedules	Estimated Value	Item/Category	Quantity
Schedule 1	573600	Porcelain Insulators For Overhead Power Lines With A Nominal Voltage Greater Than 1000 V As Per Is: 731	717
Schedule 2	80000	Porcelain Insulators For Overhead Power Lines With A Nominal Voltage Greater Than 1000 V As Per Is: 731	50
Schedule 3	62500	Porcelain Insulators For Overhead Power Lines With A Nominal Voltage Greater Than 1000 V As Per Is: 731	50
Schedule 4	99972	Porcelain Insulators For Overhead Power Lines With A Nominal Voltage Greater Than 1000 V As Per Is: 731	2

Porcelain Insulators For Overhead Power Lines With A Nominal Voltage Greater Than 1000 V As Per IS: 731 (717 pieces)

Brand Type	Registered Brand
------------	------------------

Technical Specifications

[* As per GeM Category Specification](#)

Specification	Specification Name	Bid Requirement (Allowed Values)
GENERIC	Classification of insulators	Type A, Type B
	Type	Rigid - Pin Insulator
CONSTRUCTION	Insulator for (Minimum creepage distance as per Table 3 of IS:731:1971 latest)	Moderately Polluted atmospheres, Heavily polluted atmospheres
	Highest system voltage (in kV rms)	36
	Minimum failing loads (in KN)	10 (for pin insulator)
	Installation and Commissioning	No

Specification	Specification Name	Bid Requirement (Allowed Values)
	Warranty (in Years)	1
CERTIFICATIONS	Type Test reports with 24 Hours mechanical load test for string insulators	No

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Brajendra Kumar Talukdar	786006,M/s Brahmaputra Cracker And Polymer Limited, Electrical & Department, Main Canteen Building, Lepetkata - 786006 Dibrugarh &#x 28;Assam&#x 29;	717	90

Porcelain Insulators For Overhead Power Lines With A Nominal Voltage Greater Than 1000 V As Per IS: 731 (50 pieces)

Brand Type	Registered Brand
------------	------------------

Technical Specifications

[* As per GeM Category Specification](#)

Specification	Specification Name	Bid Requirement (Allowed Values)
GENERIC	Classification of insulators	Type A, Type B
	Type	Rigid - Line post Insulator
CONSTRUCTION	Insulator for (Minimum creepage distance as per Table 3 of IS:731:1971 latest)	Moderately Polluted atmospheres, Heavily polluted atmospheres
	Highest system voltage (in kV rms)	36
	Minimum failing loads (in KN)	10 (for line post insulator)
	Installation and Commissioning	No
	Warranty (in Years)	1

Specification	Specification Name	Bid Requirement (Allowed Values)
CERTIFICATIONS	Type Test reports with 24 Hours mechanical load test for string insulators	No

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Brajendra Kumar Talukdar	786006,M/s Brahmaputra Cracker And Polymer Limited, Electrical & Department, Main Canteen Building, Lepetkata - 786006 Dibrugarh (Assam)	50	90

Porcelain Insulators For Overhead Power Lines With A Nominal Voltage Greater Than 1000 V As Per IS: 731 (50 pieces)

Brand Type	Registered Brand
------------	------------------

Technical Specifications

[* As per GeM Category Specification](#)

Specification	Specification Name	Bid Requirement (Allowed Values)
GENERIC	Classification of insulators	Type B
	Type	String insulator unit, Rigid - Pin Insulator
CONSTRUCTION	Insulator for (Minimum creepage distance as per Table 3 of IS:731:1971 latest)	Moderately Polluted atmospheres, Heavily polluted atmospheres
	Highest system voltage (in kV rms)	36
	Minimum failing loads (in KN)	70 (for string insulator)
	Installation and Commissioning	No
	Warranty (in Years)	1
CERTIFICATIONS	Type Test reports with 24 Hours mechanical load test for string insulators	No

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Brajendra Kumar Talukdar	786006,M/s Brahmaputra Cracker And Polymer Limited, Electrical & Department, Main Canteen Building, Lepetkata - 786006 Dibrugarh (Assam)	50	90

Porcelain Insulators For Overhead Power Lines With A Nominal Voltage Greater Than 1000 V As Per IS: 731 (2 pieces)

Brand Type	Unbranded
------------	-----------

Technical Specifications

[* As per GeM Category Specification](#)

Specification	Specification Name	Bid Requirement (Allowed Values)
GENERIC	Classification of insulators	Type A
	Type	Rigid - Line post Insulator
CONSTRUCTION	Insulator for (Minimum creepage distance as per Table 3 of IS:731:1971 latest)	Moderately Polluted atmospheres, Heavily polluted atmospheres
	Highest system voltage (in kV rms)	36
	Minimum failing loads (in KN)	10 (for line post insulator), 45 (for string insulator)
	Installation and Commissioning	No
	Warranty (in Years)	1
CERTIFICATIONS	Type Test reports with 24 Hours mechanical load test for string insulators	Yes, No

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Brajendra Kumar Talukdar	786006,M/s Brahmaputra Cracker And Polymer Limited, Electrical & Department, Main Canteen Building, Lepetkata - 786006 Dibrugarh (Assam)	2	90

Buyer added Bid Specific Additional Specification - Drawings

S.No.	Document Title	Description	Applicable i.r.o. Items
1	specifications of the product View	Technical specifications of the product	Porcelain Insulators For Overhead Power Lines With A Nominal Voltage Greater Than 1000 V As Per IS: 731 (717),Porcelain Insulators For Overhead Power Lines With A Nominal Voltage Greater Than 1000 V As Per IS: 731 (50),Porcelain Insulators For Overhead Power Lines With A Nominal Voltage Greater Than 1000 V As Per IS: 731 (50),Porcelain Insulators For Overhead Power Lines With A Nominal Voltage Greater Than 1000 V As Per IS: 731 (2)
2	To fill data View	To fill data to be submitted along with the bid along with drawing of the offered item.	Porcelain Insulators For Overhead Power Lines With A Nominal Voltage Greater Than 1000 V As Per IS: 731 (717),Porcelain Insulators For Overhead Power Lines With A Nominal Voltage Greater Than 1000 V As Per IS: 731 (50),Porcelain Insulators For Overhead Power Lines With A Nominal Voltage Greater Than 1000 V As Per IS: 731 (50),Porcelain Insulators For Overhead Power Lines With A Nominal Voltage Greater Than 1000 V As Per IS: 731 (2)

Buyer added Bid Specific Additional Scope of Work

S.No.	Document Title	Description	Applicable i.r.o. Items
-------	----------------	-------------	-------------------------

S.No.	Document Title	Description	Applicable i.r.o. Items
1	special conditions of contract View	special conditions of contract for the supply of the materials	Porcelain Insulators For Overhead Power Lines With A Nominal Voltage Greater Than 1000 V As Per IS: 731 (717), Porcelain Insulators For Overhead Power Lines With A Nominal Voltage Greater Than 1000 V As Per IS: 731 (50), Porcelain Insulators For Overhead Power Lines With A Nominal Voltage Greater Than 1000 V As Per IS: 731 (50), Porcelain Insulators For Overhead Power Lines With A Nominal Voltage Greater Than 1000 V As Per IS: 731 (2)

The uploaded document only contains Buyer specific Additional Scope of Work and / or Drawings for the bid items added with due approval of Buyer's competent authority. Buyer has certified that these additional scope and drawings are generalized and would not lead to any restrictive bidding.

Buyer Added Bid Specific Terms and Conditions

1. Buyer Added Bid Specific ATC

Buyer uploaded ATC document [Click here to view the file.](#)

Disclaimer

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization. Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specification and / or terms and conditions governing the bid. Any clause incorporated by the Buyer such as demanding Tender Sample, incorporating any clause against the MSME policy and Preference to make in India Policy, mandating any Brand names or Foreign Certification, changing the default time period for Acceptance of material or payment timeline governed by OM of Department of Expenditure shall be null and void and would not be considered part of bid. Further any reference of conditions published on any external site or reference to external documents / clauses shall also be null and void. If any seller has any objection / grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

[This Bid is also governed by the General Terms and Conditions](#)

In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

---Thank You---