

Bid Document/ बिड दस्तावेज़

Bid Details/बिड विवरण	
Bid End Date/Time/बिड बंद होने की तारीख/समय	27-02-2023 15:00:00
Bid Opening Date/Time/बिड खुलने की तारीख/समय	27-02-2023 15:30:00
Bid Offer Validity (From End Date)/बिड पेशकश वैधता (बंद होने की तारीख से)	90 (Days)
Ministry/State Name/मंत्रालय/राज्य का नाम	Ministry Of Petroleum And Natural Gas
Department Name/विभाग का नाम	Brahmaputra Cracker And Polymer Limited
Organisation Name/संगठन का नाम	Brahmaputra Cracker And Polymer Limited
Office Name/कार्यालय का नाम	Lepetkata
Total Quantity/कुल मात्रा	8000
Item Category/मद केटेगरी	XLPE Cable for working voltages upto and including 1.1 KV - IS - 7098 (Part 1) (Q2) , XLPE Cables for Working Voltages from 3.3 kV up to and Including 33 kV as per IS:7098 Part 2 (Q3)
Minimum Average Annual Turnover of the bidder (For 3 Years)/बिडर का न्यूनतम औसत वार्षिक टर्नओवर (3 वर्षों का)	20 Lakh (s)
Years of Past Experience Required for same/similar service/उन्हीं/समान सेवाओं के लिए अपेक्षित विगत अनुभव के वर्ष	2 Year (s)
MSE Exemption for Years of Experience/अनुभव के वर्षों से एमएसई छूट/ and Turnover	No
Startup Exemption for Years Of Experience/अनुभव के वर्षों से स्टार्टअप छूट/ and Turnover	Yes
Document required from seller/विक्रेता से मांगे गए दस्तावेज़	Experience Criteria,Bidder Turnover,Additional Doc 1 (Requested in ATC),Additional Doc 2 (Requested in ATC),Additional Doc 3 (Requested in ATC),Additional Doc 4 (Requested in ATC) *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
Bid to RA enabled/बिड से रिवर्स नीलामी सक्रिय किया	No

Bid Details/बिड विवरण	
Type of Bid/बिड का प्रकार	Two Packet Bid
Primary product category	XLPE Cable for working voltages upto and including 1.1 KV - IS - 7098 (Part 1)
Time allowed for Technical Clarifications during technical evaluation/तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय	7 Days
Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)	No
Evaluation Method/मूल्यांकन पद्धति	Item wise evaluation/

EMD Detail/ईएमडी विवरण

Advisory Bank/एडवाइजरी बैंक	ICICI
Schedule 1 EMD Amount/ईएमडी राशि (In INR)	9490
Schedule 2 EMD Amount/ईएमडी राशि (In INR)	5220
Schedule 3 EMD Amount/ईएमडी राशि (In INR)	4628
Schedule 4 EMD Amount/ईएमडी राशि (In INR)	1438
Schedule 5 EMD Amount/ईएमडी राशि (In INR)	8800
Schedule 6 EMD Amount/ईएमडी राशि (In INR)	20100
Schedule 7 EMD Amount/ईएमडी राशि (In INR)	12800
Schedule 8 EMD Amount/ईएमडी राशि (In INR)	12798
Schedule 9 EMD Amount/ईएमडी राशि (In INR)	7000

ePBG Detail/ईपीबीजी विवरण

Advisory Bank	ICICI
ePBG Percentage(%) / ईपीबीजी प्रतिशत (%)	3.00
Duration of ePBG required (Months) / ईपीबीजी की अपेक्षित अवधि (महीने).	27

(a). EMD EXEMPTION: The bidder seeking EMD exemption, must submit the valid supporting document for the relevant category as per GeM GTC with the bid. Under MSE category, only manufacturers for goods and Service Providers for Services are eligible for exemption from EMD. Traders are excluded from the purview of this Policy./जेम की शर्तों के अनुसार ईएमडी छूट के इच्छुक बिडर को संबंधित कैटेगरी के लिए बिड के साथ वैध समर्थित दस्तावेज प्रस्तुत करने हैं। एमएसई कैटेगरी के अंतर्गत केवल वस्तुओं के लिए विनिर्माता तथा सेवाओं के लिए सेवा प्रदाता ईएमडी से छूट के पात्र हैं। व्यापारियों को इस नीति के दायरे से बाहर रखा गया है।

(b). The EMD Amount will be applicable for each schedule/group selected during Bid creation.

(c). EMD & Performance security should be in favour of Beneficiary, wherever it is applicable./ईएमडी और संपादन जमानत राशि, जहां यह लागू होती है, लाभार्थी के पक्ष में होनी चाहिए।

Beneficiary/लाभार्थी :

Senior Manager (C&P)

Brahmaputra Cracker and Polymer Limited (A Government of India Enterprise), C&P Department, Administrative Building, PO: Lepetkata, Distt.: DIBRUGARH, Assam, Pin Code:786006, India
(Debajyoti Das)

Splitting/विभाजन

Bid splitting not applied.

MII Purchase Preference/एमआईआई खरीद वरीयता

MII Purchase Preference/एमआईआई खरीद वरीयता	No
--	----

Details of the Competent Authority for MII

Name of Competent Authority	PRANJAL KUMAR PHUKAN
Designation of Competent Authority	CHIEF MANAGER(CM)
Office / Department / Division of Competent Authority	CONTRACTS & PROCUREMENT(C&P)
CA Approval Number	As per Procedure
Competent Authority Approval Date	21-01-2023
Brief Description of the Approval Granted by Competent Authority	Not applicable as per procedure since the estimated value is less than 1 (One) crore.

Competent Authority Approval for not opting Make In India Preference : [View Document](#)

MSE Purchase Preference/एमएसई खरीद वरीयता

MSE Purchase Preference/एमएसई खरीद वरीयता	Yes
---	-----

1. If the bidder is a Startup, the bidder shall be exempted from the requirement of "Bidder Turnover" criteria and "Experience Criteria" subject to their meeting of quality and technical specifications. If the bidder is OEM of the offered products, it would be exempted from the "OEM Average Turnover" criteria also subject to meeting of quality and technical specifications. In case any bidder is seeking exemption from Turnover / Experience Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer.
2. The minimum average annual financial turnover of the bidder during the last three years, ending on 31st March of the previous financial year, should be as indicated above in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the bidder is less than 3-year-old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.
3. Experience Criteria: In respect of the filter applied for experience criteria, the Bidder or its OEM {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any

Central / State Govt Organization / PSU / Public Listed Company for number of Financial years as indicated above in the bid document before the bid opening date. Copies of relevant contracts to be submitted along with bid in support of having supplied some quantity during each of the Financial year. In case of bunch bids, the category of primary product having highest value should meet this criterion.

4. Purchase preference to Micro and Small Enterprises (MSEs): Purchase preference will be given to MSEs as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail the Purchase preference, the bidder must be the manufacturer of the offered product in case of bid for supply of goods. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service. If L-1 is not an MSE and MSE Seller (s) has/have quoted price within L-1+ 15% (Selected by Buyer) of margin of purchase preference /price band defined in relevant policy, such Seller shall be given opportunity to match L-1 price and contract will be awarded for 25%(selected by Buyer) percentage of total QUANTITY.

5. Estimated Bid Value indicated above is being declared solely for the purpose of guidance on EMD amount and for determining the Eligibility Criteria related to Turn Over, Past Performance and Project / Past Experience etc. This has no relevance or bearing on the price to be quoted by the bidders and is also not going to have any impact on bid participation. Also this is not going to be used as a criteria in determining reasonableness of quoted prices which would be determined by the buyer based on its own assessment of reasonableness and based on competitive prices received in Bid / RA process.

Pre Bid Detail(s)

Pre-Bid Date and Time	Pre-Bid Venue
15-02-2023 15:00:00	Through Video Conference on prior intimation of participation by interested bidders to the undersigned. Brahmaputra Cracker and Polymer Limited, C&P Department, Administrative Building, PO: Lepetkata, Distt.: DIBRUGARH, Assam, Pin Code: 786006, Phone No. 0373 2914636; Mobile No.: 8811047616 OR Query if any may be forwarded to e-mail id debajyoti@bcplindia.co.in On or before Pre-Bid date & time mentioned in GeM bidding document. Comment/ clarification on the query shall be sent on E-mail.

Evaluation Method (Item Wise Evaluation Method)

Contract will be awarded schedulewise and the determination of L1 will be done separately for each schedule. The details of item-consignee combination covered under each schedule are as under:

Evaluation Schedules	Item/Category	Quantity
Schedule 1	XLpe Cable For Working Voltages Upto And Including 1.1 Kv - Is - 7098 (part 1)	1000
Schedule 2	XLpe Cable For Working Voltages Upto And Including 1.1 Kv - Is - 7098 (part 1)	1000
Schedule 3	XLpe Cable For Working Voltages Upto And Including 1.1 Kv - Is - 7098 (part 1)	1000
Schedule 4	XLpe Cable For Working Voltages Upto And Including 1.1 Kv - Is - 7098 (part 1)	500
Schedule 5	XLpe Cable For Working Voltages Upto And Including 1.1 Kv - Is - 7098 (part 1)	1000
Schedule 6	XLpe Cables For Working Voltages From 3.3 Kv Up To And Including 33 Kv As Per Is:7098 Part 2	500
Schedule 7	XLpe Cables For Working Voltages From 3.3 Kv Up To And Including 33 Kv As Per Is:7098 Part 2	1000
Schedule 8	XLpe Cable For Working Voltages Upto And Including 1.1 Kv - Is - 7098 (part 1)	1000
Schedule 9	XLpe Cable For Working Voltages Upto And Including 1.1 Kv - Is - 7098 (part 1)	1000

XLPE Cable For Working Voltages Upto And Including 1.1 KV - IS - 7098 (Part 1) (1000 meter)

Brand Type/ब्रांड का प्रकार	Registered Brand
-----------------------------	------------------

Technical Specifications/तकनीकी विशिष्टियाँ

* As per GeM Category Specification/जेम कैटेगरी विशिष्टि के अनुसार

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Conformity of the specification for XLPE cable	as per IS:7098 (Part 1): 1988 latest
	Cables suitable for use in mines	No
	Cables suitable for use in low temperature applications	Yes
GENERIC	Classification of cables for improved fire performance category	01
	Nominal Area of Conductor (in Sq. mm)	16
	Number of core (in Nos.)	3
CONSTRUCTION	Material of conductor	Plain Copper
	Type of inner sheath	Thermoplastic
ARMOURING	Type of cable	Armoured cable
	Material of armouring	Galvanized steel formed wire
	Type of armouring	Single strip
CERTIFICATION	Availability of Optional Test Reports	Cold bend test for outer sheath, Cold impact test for outer sheath, Resistance test for Armour, Not applicable

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
----------------	---	-------------	-----------------	------------------------------

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Arindam Raj Handique	785688, CONTRACTS AND PROCUREMENT DEPARTMENT CENTRAL WARE HOUSE BRAHMAPUTRA CRACKER & POLYMER LIMITED C2+ RECOVERY PLANT, LAKWA CHARAIDEO-785688, ASSAM (INDIA)	1000	90

XLPE Cable For Working Voltages Upto And Including 1.1 KV - IS - 7098 (Part 1) (1000 meter)

Brand Type/ब्रांड का प्रकार	Registered Brand
-----------------------------	------------------

Technical Specifications/तकनीकी विशिष्टियाँ

* As per GeM Category Specification/जेम कैटेगरी विशिष्टि के अनुसार

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Conformity of the specification for XLPE cable	as per IS:7098 (Part 1): 1988 latest
	Cables suitable for use in mines	No
	Cables suitable for use in low temperature applications	No
GENERIC	Classification of cables for improved fire performance category	01
	Nominal Area of Conductor (in Sq. mm)	25
	Number of core (in Nos.)	3.5
CONSTRUCTION	Material of conductor	Aluminium
	Type of inner sheath	Thermoplastic
ARMOURING	Type of cable	Armoured cable
	Material of armouring	Galvanized steel formed wire
	Type of armouring	Single strip
CERTIFICATION	Availability of Optional Test Reports	Cold bend test for outer sheath, Cold impact test for outer sheath, Resistance test for Armour, Not applicable

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Arindam Raj Handique	785688, CONTRACTS AND PROCUREMENT DEPARTMENT CENTRAL WARE HOUSE BRAHMAPUTRA CRACKER & POLYMER LIMITED C2+ RECOVERY PLANT, LAKWA CHARAIDEO-785688, ASSAM (INDIA)	1000	90

XLPE Cable For Working Voltages Upto And Including 1.1 KV - IS - 7098 (Part 1) (1000 meter)

Brand Type/ब्रांड का प्रकार	Registered Brand
-----------------------------	------------------

Technical Specifications/तकनीकी विशिष्टियाँ

* As per GeM Category Specification/जेम केटेगरी विशिष्टि के अनुसार

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Conformity of the specification for XLPE cable	as per IS:7098 (Part 1): 1988 latest
	Cables suitable for use in mines	No
	Cables suitable for use in low temperature applications	Yes
GENERIC	Classification of cables for improved fire performance category	01
	Nominal Area of Conductor (in Sq. mm)	6
	Number of core (in Nos.)	3
CONSTRUCTION	Material of conductor	Plain Copper
	Type of inner sheath	Thermoplastic
ARMOURING	Type of cable	Armoured cable
	Material of armouring	Galvanized steel formed wire

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Type of armouring	Single strip
CERTIFICATION	Availability of Optional Test Reports	Cold bend test for outer sheath, Cold impact test for outer sheath, Resistance test for Armour, Not applicable

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Arindam Raj Handique	785688, CONTRACTS AND PROCUREMENT DEPARTMENT CENTRAL WARE HOUSE BRAHMAPUTRA CRACKER & POLYMER LIMITED C2+ RECOVERY PLANT, LAKWA CHARAIDEO-785688, ASSAM (INDIA)	1000	90

XLPE Cable For Working Voltages Upto And Including 1.1 KV - IS - 7098 (Part 1) (500 meter)

Brand Type/ब्रांड का प्रकार	Registered Brand
-----------------------------	------------------

Technical Specifications/तकनीकी विशिष्टियाँ

* As per GeM Category Specification/जेम कैटेगरी विशिष्टि के अनुसार

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Conformity of the specification for XLPE cable	as per IS:7098 (Part 1): 1988 latest
	Cables suitable for use in mines	No
	Cables suitable for use in low temperature applications	Yes
GENERIC	Classification of cables for improved fire performance category	01

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Nominal Area of Conductor (in Sq. mm)	2.5
	Number of core (in Nos.)	4
CONSTRUCTION	Material of conductor	Plain Copper
	Type of inner sheath	Thermoplastic
ARMOURING	Type of cable	Armoured cable
	Material of armouring	Galvanized steel formed wire
	Type of armouring	Single strip
CERTIFICATION	Availability of Optional Test Reports	Cold bend test for outer sheath, Cold impact test for outer sheath, Resistance test for Armour, Not applicable

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Arindam Raj Handique	785688, CONTRACTS AND PROCUREMENT DEPARTMENT CENTRAL WARE HOUSE BRAHMAPUTRA CRACKER & POLYMER LIMITED C2+ RECOVERY PLANT, LAKWA CHARAIDEO-785688, ASSAM (INDIA)	500	90

XLPE Cable For Working Voltages Upto And Including 1.1 KV - IS - 7098 (Part 1) (1000 meter)

Brand Type/ब्रांड का प्रकार	Registered Brand
-----------------------------	------------------

Technical Specifications/तकनीकी विशिष्टियाँ

* As per GeM Category Specification/जेम कैटेगरी विशिष्टि के अनुसार

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
---------------	------------------------------------	--

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Conformity of the specification for XLPE cable	as per IS:7098 (Part 1): 1988 latest
	Cables suitable for use in mines	Yes
	Cables suitable for use in low temperature applications	Yes
GENERIC	Classification of cables for improved fire performance category	01
	Nominal Area of Conductor (in Sq. mm)	2.5
	Number of core (in Nos.)	7
CONSTRUCTION	Material of conductor	Plain Copper
	Type of inner sheath	Thermoplastic
ARMOURING	Type of cable	Armoured cable
	Material of armouring	Galvanized steel formed wire
	Type of armouring	Single wire
CERTIFICATION	Availability of Optional Test Reports	Cold bend test for outer sheath, Cold impact test for outer sheath, Resistance test for Armour, Not applicable

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Arindam Raj Handique	785688, CONTRACTS AND PROCUREMENT DEPARTMENT CENTRAL WARE HOUSE BRAHMAPUTRA CRACKER & POLYMER LIMITED C2+ RECOVERY PLANT, LAKWA CHARAIDEO-785688, ASSAM (INDIA)	1000	90

XLPE Cables For Working Voltages From 3.3 KV Up To And Including 33 KV As Per IS:7098 Part 2 (500 meter)

Brand Type/ब्रांड का प्रकार	Registered Brand
-----------------------------	------------------

Technical Specifications/तकनीकी विशिष्टियाँ

* As per GeM Category Specification/जेम कैटेगरी विशिष्टि के अनुसार

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
GENERIC	Types of cable	Three-core armoured, screened
	Voltage Grade	Earthed systems: 6.35/11 kV
	Armoured cables upto 11 kV Grade specified in this standard are suitable for use in mines (as per Cl. 1.3 , 4.1.1, Cl. 17.5 and Cl. 21.2.1 of IS:7098 (Part 2):2011 (If "Yes" manufacturer shall have valid BIS License for the same)	Yes
	Low temperature application (If "Yes" manufacturer shall have valid BIS License for the same)	Yes
	Conductor material (as per Cl.4 of IS:7098 (Part 2):2011 latest	Aluminium
	Outer sheath (Type ST2)	PVC
	"Nominal Area of Conductor (in Sq.mm)	300
CONSTRUCTIONAL	Armouring	Galvanized round steel wire armoured
	Cable packing type (Wound on drum) (as per Cl. 22.1 of I:7098 (Part 2):2011 latest	Wooden drum

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
----------------	---	-------------	-----------------	------------------------------

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Arindam Raj Handique	785688, CONTRACTS AND PROCUREMENT DEPARTMENT CENTRAL WARE HOUSE BRAHMAPUTRA CRACKER & POLYMER LIMITED C2+ RECOVERY PLANT, LAKWA CHARAIDEO-785688, ASSAM (INDIA)	500	90

XLPE Cables For Working Voltages From 3.3 KV Up To And Including 33 KV As Per IS:7098 Part 2 (1000 meter)

Brand Type/ब्रांड का प्रकार	Registered Brand
-----------------------------	------------------

Technical Specifications/तकनीकी विशिष्टियाँ

[* As per GeM Category Specification/जेम कैटेगरी विशिष्टि के अनुसार](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
GENERIC	Types of cable	Single-core armoured (non-magnetic) screened
	Voltage Grade	Earthed systems: 19/33 kV
	Armoured cables upto 11 kV Grade specified in this standard are suitable for use in mines (as per Cl. 1.3 , 4.1.1, Cl. 17.5 and Cl. 21.2.1 of IS:7098 (Part 2):2011 (If "Yes" manufacturer shall have valid BIS License for the same)	Yes
	Low temperature application (If "Yes" manufacturer shall have valid BIS License for the same)	Yes
	Conductor material (as per Cl.4 of IS:7098 (Part 2):2011 latest	Aluminium
	Outer sheath (Type ST2)	PVC
	"Nominal Area of Conductor (in Sq.mm)	185
CONSTRUCTIONAL	Armouring	Galvanized round steel wire armoured
	Cable packing type (Wound on drum) (as per Cl. 22.1 of I:7098 (Part 2):2011 latest	Wooden drum

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Arindam Raj Handique	785688, CONTRACTS AND PROCUREMENT DEPARTMENT CENTRAL WARE HOUSE BRAHMAPUTRA CRACKER & POLYMER LIMITED C2+ RECOVERY PLANT, LAKWA CHARAIDEO-785688, ASSAM (INDIA)	1000	90

XLPE Cable For Working Voltages Upto And Including 1.1 KV - IS - 7098 (Part 1) (1000 meter)

Brand Type/ब्रांड का प्रकार	Registered Brand
-----------------------------	------------------

Technical Specifications/तकनीकी विशिष्टियाँ

[* As per GeM Category Specification/जेम कैटेगरी विशिष्टि के अनुसार](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Conformity of the specification for XLPE cable	as per IS:7098 (Part 1): 1988 latest
	Cables suitable for use in mines	No
	Cables suitable for use in low temperature applications	No
GENERIC	Classification of cables for improved fire performance category	01
	Nominal Area of Conductor (in Sq. mm)	16
	Number of core (in Nos.)	4
CONSTRUCTION	Material of conductor	Plain Copper
	Type of inner sheath	Thermoplastic
ARMOURING	Type of cable	Armoured cable

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Material of armouring	Galvanized steel formed wire
	Type of armouring	Single wire
CERTIFICATION	Availability of Optional Test Reports	Cold bend test for outer sheath, Cold impact test for outer sheath, Resistance test for Armour, Not applicable

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Arindam Raj Handique	785688, CONTRACTS AND PROCUREMENT DEPARTMENT CENTRAL WARE HOUSE BRAHMAPUTRA CRACKER & POLYMER LIMITED C2+ RECOVERY PLANT, LAKWA CHARAIDEO-785688, ASSAM (INDIA)	1000	90

XLPE Cable For Working Voltages Upto And Including 1.1 KV - IS - 7098 (Part 1) (1000 meter)

Brand Type/ब्रांड का प्रकार	Registered Brand
-----------------------------	------------------

Technical Specifications/तकनीकी विशिष्टियाँ

* As per GeM Category Specification/जेम कैटेगरी विशिष्टि के अनुसार

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Conformity of the specification for XLPE cable	as per IS:7098 (Part 1): 1988 latest
	Cables suitable for use in mines	No
	Cables suitable for use in low temperature applications	Yes

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
GENERIC	Classification of cables for improved fire performance category	01
	Nominal Area of Conductor (in Sq. mm)	2.5
	Number of core (in Nos.)	12
CONSTRUCTION	Material of conductor	Plain Copper
	Type of inner sheath	Thermoplastic
ARMOURING	Type of cable	Armoured cable
	Material of armouring	Galvanized steel formed wire
	Type of armouring	Single strip
CERTIFICATION	Availability of Optional Test Reports	Cold bend test for outer sheath, Cold impact test for outer sheath, Resistance test for Armour, Not applicable

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Arindam Raj Handique	785688, CONTRACTS AND PROCUREMENT DEPARTMENT CENTRAL WARE HOUSE BRAHMAPUTRA CRACKER & POLYMER LIMITED C2+ RECOVERY PLANT, LAKWA CHARAIDEO-785688, ASSAM (INDIA)	1000	90

Buyer Added Bid Specific Terms and Conditions/क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें

1. Scope of Supply

Scope of supply (Bid price to include all cost components) : Only supply of Goods

2. Buyer Added Bid Specific ATC

Buyer Added text based ATC clauses

1. Bidder must read carefully the 'Buyer uploaded ATC document' (which consists of the BCPL Tender Document with Bid Evaluation Criteria (BEC), Bid Evaluation Methodology, Instructions to bidders with applicable form & formats, GPC, SCC, Technical Specifications, Drawings/datasheets etc.) along with other terms & conditions of bid document including General Terms & Conditions (GTC) GeM before quoting.
2. In case of any conflict between "BCPL Tender Document attached in 'Buyer uploaded ATC document' of the GeM Bid Document" and GeM GTC/GeM Bid Document, tender conditions as per the "BCPL Tender Document" shall prevail.
3. The quoted price shall be inclusive of P&F, Freight charges upto Consignee Address and all taxes & duties. As such, no additional charges such as packing & forwarding/ transportation / loading charges/transit insurance/GST/ local levies etc. shall be payable over and above the quoted/contract price.
4. Any charges payable to GeM shall be borne by the bidder.

3. Buyer Added Bid Specific ATC

Buyer uploaded ATC document [Click here to view the file.](#)

Disclaimer/अस्वीकरण

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. Any clause(s) incorporated by the Buyer regarding following shall be treated as null and void and would not be considered as part of bid:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process.
9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

This Bid is also governed by the General Terms and Conditions/ यह बिड सामान्य शर्तों के अंतर्गत भी शासित है

In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws./जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्यवाई का आधार होगा।

---Thank You/धन्यवाद---