



BRAHMAPUTRA CRACKER AND POLYMER LIMITED

[A Govt. of India Enterprise]

SCC: DWPE-Bio

1. Delivery Schedule:

1.i The material to be delivered to M/s BCPL, Lepetkata in a single lot.

QUANTITY	DELIVERY TO START AFTER	DELIVERY TO BE COMPLETED BY
700	1	30

2. Quantity & Packing:

700 KG. The material shall be supplied in packing as suitable (air tight bags) for supply of DWPE-Bio in 25 KG poly bags.

3. Guarantee/Warranty:

All goods or material shall be supplied strictly in accordance with the technical specifications as stated in the tender/order. Material should be guaranteed against defective materials/workmanship till it is unloaded at BCPL's site. Confirmation that the GOODS shall be guaranteed against non-conforming specifications/quality for a period of 12 months from the date of dispatch of the required quantity in each lot. If at any point of time, the material is not found suitable for use or is found to be of inferior quality, the material shall be taken back by the SELLER at his own cost and material replaced immediately.

Testing of supplied material:

On delivery of the chemical by the vendor, testing shall be done in BCPL, Laboratory, Lepetkata before accepting the chemical. If at any point of time, the material is not found suitable for use or is found to be of inferior quality, the material shall be taken back by the SELLER at his own cost and material replaced immediately. The result of the testing done at BCPL, Laboratory shall be considered as final & binding.

4. Weights And Measurements:

All weights and measurements recorded by the Purchaser on receipt of goods at BCPL's site will be treated as final. Payment shall be made on actual quantity receipt at BCPL site basis.

5. Dispatch Documents:

- 1) Tax Invoice (Original)
- 2) Excise invoice (if applicable) to be sent along with the truck.
- 3) Delivery Challan /Original LR
- 4) Test Certificate/Analysis report
- 5) Warranty/Guarantee Certificate

6. Inspection / Certificate Of Analysis:

Each supply (Lot) of material shall be accompanied by **MSDS, Certificate of Analysis (COA) & Warranty/ Guarantee Certificate**. COA should be in line with BCPL's required specification i.e. COA should contain analysis report of all the technical specifications. Supplier should submit manufacturer's test certificate along with each consignment, clearly



BRAHMAPUTRA CRACKER AND POLYMER LIMITED

[A Govt. of India Enterprise]

indicating the relevant parameters on the letter head from the manufacturer with proper company seal.

Technical Specifications of Dewatering Polyelectrolyte (DWPE-Bio)

De-Watering Polyelectrolyte –Bio (DWPE-BIO)

Application: Dewatering of organic sludge from sewage, human waste, etc

Material	: De-Watering Polyelectrolyte –Bio (DWPE-BIO)
Major Content	: Polyacrylic Ester
Shape	: White Granules
Bulk density(gm/cc)	:0.63
Dissolution conc(%)	:0.1-0.3
Effective pH range	:4-9
Aq Solution pH (0.1%)	:3 – 6
Viscosity 0.1% at 25 0C (mP a.s)	: 360
Packing	: 25 kg poly bags
Quantity	: 700 KGS