

अर्थिंग डालने के लिए विनिर्देश

SPECIFICATION FOR EARTHING INSTALLATION

4	26.03.14	REVISED AND ISSUED AS SPECIFICATION	FA	SA	BRB	SC
3	25.04.08	REVISED AND ISSUED AS SPECIFICATION	RKS	SSM	JMS	VC
2	28.02.03	REVISED & ISSUED AS SPECIFICATION	HKM	RSG	VPS	SKG
1	16.07.97	REVISED & ISSUED AS STANDARD SPECIFICATION	RR	VPS	SG	AS
0	25.07.94	ISSUED AS STANDARD SPECIFICATION	RR	SGC	SCG	SCG
Rev. No	Date	Purpose	Prepared by	Checked by	Standards Committee Convenor	Standards Bureau Chairman
Approved by						

Abbreviations:

BIS	:	Bureau of Indian Standards
PESO	:	Petroleum and Explosive safety organization.
CD	:	Compact Disc
CEA	:	Central Electricity Authority
DGMS	:	Director General Mines and Safety
GI	:	Galvanized Iron
IS	:	Indian Standard
MS	:	Mild Steel
OISD	:	Oil Industry Safety Directorate
UPS	:	Uninterrupted Power Supply

Electrical Standards Committee

Convenor: Mr. BR Bhogal

Members: Ms. S. Anand
Mr. Parag Gupta
Mr. M.K. Sahu
Mr. A.K. Chaudhary (Inspection)
Ms. N.P. Guha (Projects)

CONTENTS

1.0	SCOPE.....	4
2.0	CODES AND STANDARDS.....	4
3.0	MATERIAL SPECIFICATIONS.....	4
4.0	EARTHING NETWORK.....	4
5.0	INSTALLATION OF EARTH ELECTRODE.....	5
6.0	CONNECTION.....	6
7.0	TESTING AND COMMISSIONING.....	7

1.0 SCOPE

This specification defines the requirements for the supply of earthing and lightning protection materials and installation of the earthing and lightning protection systems.

2.0 CODES AND STANDARDS

2.1 The work shall be carried out in the best workman like manner in conformity with this specification, EIL Installation Standards, layout drawings, the latest edition of relevant specifications, codes of practice of Bureau of Indian Standards and OISD Standards listed below :

SP:30 (BIS)	Special Publication-National Electrical Code
IS:2309	Protection of buildings and allied structures against lightning.
IS:3043	Code of practice for earthing
IS:7689	Guide for control of undesirable static electricity.
OISD 110	Recommended practices on static electricity
OISD 147	Inspection and safe practice during electrical installation.
OISD GDN 180	Lightning protection.

2.2 In addition to the above it shall be ensured that the installation conforms to the requirements of the following as applicable:

- a. CEA Regulations
- b. Regulations laid down by CEA/Electrical Inspectorate.
- c. Regulations laid down by PESO/DGMS (as applicable).
- d. The petroleum rules (Ministry of Industry Government of India).
- e. Any other regulations laid down by central/state/local authorities and Insurance agencies.

3.0 MATERIAL SPECIFICATIONS

3.1 All materials and hardware to be supplied by the contractor shall be new, unused and of best quality and shall conform to the specifications given here under and to latest specifications of Bureau of Indian Standards. Contractor shall bring material samples to site and get it approved by Engineer-in-charge before installation.

3.2 The main earth grid conductor shall be hot dip galvanised M.S. flat unless otherwise specified. Sizes for main conductors shall be as indicated on the earthing layout drawing .Amount of galvanizing shall be 610gm per sq.metre. Earth electrodes and Earth plate shall be as per EIL Installation Standards.

4.0 EARTHING NETWORK

4.1 This consists of main earth conductor (grid conductor) forming a closed ring network with required number of earth electrodes connected to it to provide a common earth for electrical devices and metallic structures. From each earth electrode two distinct connections shall be made to the main earth conductor. The earth plates shall be used for taking multiple earth connections to two or more equipment.

4.2 The earth conductor shall be laid along cable trays/cable trench/pipe racks/ buried in

pavement/ below finished grade level as indicated on the earthing layout drawing. Where lined cable trenches are available, the earth conductor shall be preferably laid in the trenches and shall be firmly cleated to the sidewall of concrete trenches using GI clamps at interval of 400 mm to 500 mm and near to the termination end. The earthing conductor shall run along one of the cable trays along the overhead cable route. The earthing conductor shall be suitably cleated and electrically bonded to all the other cable trays on the same cable route at a regular interval of 25 to 30 meter. The earthing for equipment shall be tapped from the main earth conductor and not from cable tray support structure. Earth conductor when laid underground shall be at a depth of 500mm below finished grade level.

- 4.3** Joints and tapping's in the main earth loop shall be made in such a way that reliable and good electrical connections are permanently ensured. All joints below grade shall be welded and shall be suitably protected by giving two coats of bitumen and covering with Hessian tape. Earth strip laid above ground shall be welded across straight through joints and joints shall be suitably protected by giving two coats of bitumen to avoid oxidation and insulation film formation of the strip surface. When two earth strips are to be jointed by means of welding, lap welding with an overlapping of strip equivalent to double the width of the strip and all four sides shall be continuously welded. All joints at tapplings above ground shall be by means of connector/lugs. A minimum of two bolts of adequate size shall be used for this purpose. Earthing strip joints at earth plate and equipment shall be through GI bolts, nut etc.

5.0 INSTALLATION OF EARTH ELECTRODE

- 5.1** Earth Electrode shall be installed as shown on installation standard and layout drawings. The location shown on the layout drawings are indicative.

The exact location of earth electrodes in the field shall be determined by contractor in consultation with the Engineer-in-charge, depending on the soil strata and resistivity. Earth electrodes shall be located avoiding interferences with road, building foundation, column, pipelines etc. The civil area drawings shall be referred for this. The distance between two electrodes shall not be less than twice the depth of electrode.

- 5.2** Electrodes shall preferably be located in a moist soil which has a fine texture, grain size and distribution. Wherever practicable the soil shall be dug up, all lumps broken and stones removed from the immediate vicinity of the electrodes and soil packed by watering and ramming as tight as possible.
- 5.3** The electrodes shall have a clean surface, not covered by paint, enamel, grease or other materials of poor conductivity.
- 5.4** All earth electrodes shall be tested for earth resistance by means of standard earth test meter. The tests shall take place in dry months, preferably after a protracted dry spell.
- 5.5** The disconnect facility shall be provided for the individual earth electrode to check its earth resistance periodically.
- 5.6** Location of earth electrodes shall be marked by permanent markers for easy identification. All earth Electrodes shall be serial numbered and also marked on 'As Built' drawing for future reference.
- 5.7** Individual earth electrodes shall be provided for each lightning arrestor and flood light mast.
- 5.8** Earthing system provided for concrete paved area by other agency where applicable; shall be connected to the plant earthing system below ground by minimum two earth connections.

6.0 CONNECTION

The earth system connections shall generally cover the following:

- Equipment earthing for personnel safety
- System neutral earthing
- Static and lightning protection

6.1 The following shall be earthed.

- System neutral
- Current and potential transformer secondary neutral
- Metallic non-current carrying parts of all electrical apparatus such as transformers, switchboards, bus ducts, motors, neutral earthing resistors, capacitors, UPS, battery charger panels, welding receptacles, power sockets, lighting/power panels, control stations, lighting fixtures etc.
- Steel structures/columns, rail loading platforms etc.
- Cable trays and racks, lighting mast and poles
- Storage tanks, spheres, vessels, columns and all other process equipment.
- Fence and Gate for electrical equipment (e.g. transformer yard etc.)
- Cable shields and armour
- Flexible earth provision for Wagon, Truck
- Shield wire

Conductor size for branch connection to various equipment shall be as per EIL Installation Standards unless otherwise stated on earthing layout drawings.

- 6.2 All process pipelines shall be bonded and earthed at the entry and exist points of battery limit of hazardous area.
- 6.3 Steel pipe racks in the process units and offsite area shall be earthed at every 24 meters.
- 6.4 Equipment/street light pole etc. located remote from main earth network may be earthed by means of individual earth electrode and earth conductor unless otherwise stated in job specifications/earthing layout drawing.
- 6.5 Lightning protection shall be provided for the equipment, structures and buildings as shown on layout drawing. Self conducting structures shall not require separate aerial rod and down conductors. These shall however be connected to the earthing system at two or more points as shown on layout drawing. Each down conductor shall be provided with an earth electrode and all earth electrodes shall be interconnected through underground strip. Lightning protection earthing system may be bonded to electrical safety earthing system, inside ground. Lightning down conductor shall be brought to earth electrode in shortest straight path as feasible to minimise surge impedance.
- 6.6 The main earthing network shall be used for earthing of equipment to protect against static electricity.
- 6.7 All medium and high voltage equipment (above 250V) shall be earthed by two separate and distinct connections with earth.

- 6.8** Plant instrument system clean earthing, UPS system clean/safety earth, Data concentrator panel, HMI etc shall be separate from the electrical earthing system, if mentioned in job specification/ layout drawings.
- 6.9** All paint, scale and enamel shall be removed from the contact surface before the earthing connections are made.
- 6.10** All earthing connections for equipment earthing shall be preferably from the earth plate mounted above ground wherever provided
- Equipment foundation bolts shall not be used for earthing connection.
- 6.11** Earth connections shall be made through compression type cable lugs/by welded lugs.
- 6.12** All hardware used for earthing installation shall be hot dip galvanised or zinc passivated. Spring washers shall be used for all earthing connections and all connections adequately locked against loosening.
- 6.13** Lighting fixtures and receptacles shall be earthed through the extra core provided in the lighting circuit/cable for this purpose.
- 6.14** The reinforcements of sub-station building and the sub-station floor shall be connected to main earth grid.

7.0 TESTING AND COMMISSIONING

- 7.1** Field inspection, testing and commissioning of electrical installation shall be done as per EIL standard specification. Earthing systems/connections shall be tested as follows:
- 7.2** Resistance of individual earth electrodes shall be measured after disconnecting it from the grid by using standard earth test meggar.
- 7.3** Earthing resistance of the grid shall be measured after connecting all the earth electrodes to the grid. The resistance value of an earth grid to the general mass of earth shall be as follows:
- For the electrical system and equipment a value that ensures the operation of the protection device in the electrical circuit but not in excess of 4 ohm. However for generating stations and large sub-systems, the value shall not be more than 1 ohm.
 - For lightning protection, the value of 5ohms as earth resistance shall be desirable, but in no case it shall be more than 10 ohms.
- 7.4** The resistance to earth shall be measured typically at the following points:
- a) At each electrical system earth or system neutral earth.
 - b) At each earth provided for structure lightning protections.
 - c) At one point on earthing system used to earth electrical equipment enclosures.
 - d) At one point on earthing system used to earth wiring system, enclosures, such as metal conduits and cable sheaths or armour.
 - e) At one point on fence enclosing electrical equipment.
- 7.5** All earthing layout drawings shall be marked by contractor for 'AS BUILT STATUS' and two sets of hard copies plus 1 set of soft copy, shall be submitted to EIL. For projects, where layout drawings have been prepared based on 3D modeling, contractor shall carryout necessary changes for 'AS BUILT STATUS' in the 3D model.