







G.I. EARTH PLATE



TYPICAL INSTALLATION
OF EARTH PLATE ON
R.C.C. STRUCTURES

TYPICAL INSTALLATION
OF EARTH PLATE ON
STEEL STRUCTURES



TYPICAL FIXING DETAIL
OF G.I. EARTH STRIP
TO EARTH PLATE

NOTES:-

1. ALL DIMENSIONS ARE IN MM.
2. WHERE FIRE PROOFING OF STEEL STRUCTURES ARE ENCOUNTERED LENGTH OF CARBON STEEL BOLTS SHALL BE SUITABLY INCREASED FOR FIXING OF EARTH PLATE.
3. ALL CONNECTIONS WITH EARTH PLATE SHALL BE MADE WITH 8MM DIA. G.I. BOLT, NUT, SPRING AND PLAIN WASHERS.
4. CRIMP TYPE CABLE LUGS SHALL BE USED FOR CONNECTION WITH G.I. WIRE ROPE.

5	27.06.11	REAFFIRMED & ISSUED	BP	RKS/RSC	UAP	DM
4	31.01.07	REAFFIRMED & ISSUED	BP	RKS/AKJ	JMS	VC
Rev. No.	Date	Purpose	Prepared by	Checked by	Stds. Committee Convenor	Stds. Bureau Chairman