

Bid Document

Bid Details	
Bid End Date/Time	02-11-2020 15:00:00
Bid Opening Date/Time	02-11-2020 15:30:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	60 (Days)
Ministry/State Name	Ministry Of Chemicals And Fertilizers
Department Name	Department Of Chemicals And Petrochemicals
Organisation Name	Brahmaputra Cracker And Polymer Limited (bcpl) Guwahati Assam
Office Name	Lepetkata
Total Quantity	16500
Item Category	power cable for direct burial xlpe ugac cable , PVC Copper Cable (Heavy Duty), TYPE: C PVC Compound , Category: 01, For Working Voltages Up t
Bidder Turnover (Last 3 Years)	19 Lakh (s)
Experience Criteria	2 Year (s)
MSE Exemption for Years of Experience and Turnover	No
Startup Exemption for Years Of Experience and Turnover	Yes
Document required from seller	Experience Criteria,Bidder Turnover,Certificate (Requested in ATC),OEM Authorization Certificate *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
Bid to RA enabled	No
Primary product category	power cable for direct burial xlpe ugac cable
Inspection Required	Yes
Inspection to be carried out by Buyers own empanelled agency	Yes
Type Of Inspection	Pre Dispatch
Name of the Empanelled Inspection Agency/ Authority	Board of Officers
Estimated Bid Value	3906280

EMD Detail

Advisory Bank	ICICI
EMD Percentage(%)	2.00
EMD Amount	78126

ePBG Detail

Advisory Bank	ICICI
ePBG Percentage(%)	10.00
Duration of ePBG required (Months).	14

(a). EMD EXEMPTION: The bidder seeking EMD exemption, must submit the valid supporting document for the relevant category as per GeM GTC with the bid. Under MSE category, only manufacturers for goods and Service Providers for Services are eligible for exemption from EMD. Traders are excluded from the purview of this Policy.

(b). EMD & Performance security should be in favour of Beneficiary, wherever it is applicable.

Beneficiary:

Sr. Manager (C&P)

BRAHMAPUTRA CRACKER AND POLYMER LIMITED (A Government of India Enterprise) ADMINISTRATIVE BUILDING, PO: LEPETKATA DISTT.: DIBURGARH, ASSAM PIN CODE: 786006 PHONE NO. 0373 2914636
(Debajyoti Das)

Splitting

Bid splitting not applied.

MSE Purchase Preference

MSE Purchase Preference	Yes
-------------------------	-----

1. Experience Criteria: In respect of the filter applied for experience criteria, the Bidder or its OEM {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU / Public Listed Company for number of Financial years as indicated above in the bid document before the bid opening date. Copies of relevant contracts to be submitted along with bid in support of having supplied some quantity during each of the Financial year. In case of bunch bids, the category of primary product having highest value should meet this criterion.

2. Purchase preference to Micro and Small Enterprises (MSEs): Purchase preference will be given to MSEs as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail the Purchase preference, the bidder must be the manufacturer of the offered product in case of bid for supply of goods. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service. If L-1 is not an MSE and MSE Seller (s) has/have quoted price within L-1+ 15% of margin of purchase preference /price band defined in relevant policy, such Seller shall be given opportunity to match L-1 price and contract will be awarded for percentage of 25% of total value.

Power Cable For Direct Burial Xlpe Ugac Cable (1000 meter)**Technical Specifications**

[* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
GENERIC	Mode of Buying	Through bidding only	*
	Size of Cable (in Sq.mm)	95.0	95.0
	Number of cores	3	3

	(nos)		
	Cable Type	PVC outer Sheathed FR of Type ST-2 cable FR Grade C1 Category having heat resisting insulation of PVC compound type C with aluminum conductor suitable for rated voltage at 1100 volts grade and conforming to IS: 1554 Part-1 1988 reaffirmed 2005	PVC outer Sheathed FR of Type ST-2 cable FR Grade C1 Category having heat resisting insulation of PVC compound type C with aluminum conductor suitable for rated voltage at 1100 volts grade and conforming to IS: 1554 Part-1 1988 reaffirmed 2005
	BIS marked	yes	*
	BIS certificate number	-	*
	Armouring	Galvanised round steel wire armoured	Galvanised round steel wire armoured, Galvanised steel Strip armoured
	Armouring Type	single wire or strip armouring	single wire or strip armouring
	shape of conductor	Stranded	Stranded, Stranded and Shaped
CONSTRUCTIONAL	Number of armouring strip/wire for each size of cable	-	*
	size of armouring strip/wire for each size of cable	-	*
	Material of conductor	Aluminium EC Grade	*
	Weight of finished cable per meter	-	*
	In addition to marking requirements as per relevant specification, sequential marking for length, Size of the cable, Type of the cable and Drum Number shall be embossed on every metre of the cable	yes	*
	standard cable length on a drum	500 meter for cable size up to and including 185 sqmm.	*
	Part length which can be supplied by seller (meter)	-	*
	cable to be supplied on wooden drums conforming to IS: 10418/82 with latest amendments.	yes	*
	Quantity supplied shall not be more than the ordered quantity.	yes	*
CERTIFICATIONS	Availability of Type test report from Central government/NABL/ILAC accredited laboratory to prove conformity to the specification for minimum and maximum ratings.	yes	*

Type Test Certificate No.	-	*
Type Test Certificate date	-	*
Name of Lab	-	*
Address of Lab	-	*
Test Report to be furnished to the buyer on demand	yes	*

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Dhrupad Rajkhowa	786006,M/s Brahmaputra Cracker And Polymer Limited, Contract & Procurement Department, Administrative Building, Lepetkata - 786006 Dibrugarh (Assam)	1000	90

Power Cable For Direct Burial Xlpe Ugac Cable (2500 meter)

Technical Specifications

[* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
GENERIC	Mode of Buying	Through bidding only	*
	Size of Cable (in Sq.mm)	35.0	35.0
	Number of cores (nos)	3.5	3.5, 4
	Cable Type	PVC outer Sheathed FR of Type ST-2 cable FR Grade C1 Category having heat resisting insulation of PVC compound type C with aluminum conductor suitable for rated voltage at 1100 volts grade and conforming to IS: 1554 Part-1 1988 reaffirmed 2005	PVC outer Sheathed FR of Type ST-2 cable FR Grade C1 Category having heat resisting insulation of PVC compound type C with aluminum conductor suitable for rated voltage at 1100 volts grade and conforming to IS: 1554 Part-1 1988 reaffirmed 2005
	BIS marked	yes	*
	BIS certificate number	-	*
	Armouring	Galvanised steel Strip armoured	Galvanised steel Strip armoured
	Armouring Type	single wire or strip armouring	single wire or strip armouring
	shape of conductor	Stranded and Shaped	Stranded, Stranded and Shaped

CONSTRUCTIONAL	Number of armouring strip/wire for each size of cable	-	*
	size of armouring strip/wire for each size of cable	-	*
	Material of conductor	Aluminium EC Grade	*
	Weight of finished cable per meter	-	*
	In addition to marking requirements as per relevant specification, sequential marking for length, Size of the cable, Type of the cable and Drum Number shall be embossed on every metre of the cable	yes	*
	standard cable length on a drum	250 meter for size 240sqmm and above.	*
	Part length which can be supplied by seller (meter)	-	*
	cable to be supplied on wooden drums conforming to IS: 10418/82 with latest amendments.	yes	*
CERTIFICATIONS	Quantity supplied shall not be more than the ordered quantity.	yes	*
	Availability of Type test report from Central government/NABL/ILAC accredited laboratory to prove conformity to the specification for minimum and maximum ratings.	yes	*
	Type Test Certificate No.	-	*
	Type Test Certificate date	-	*
	Name of Lab	-	*
	Address of Lab	-	*
	Test Report to be furnished to the buyer on demand	yes	*

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days

1	Dhrupad Rajkhowa	786006,M/s Brahmaputra Cracker And Polymer Limited, Contract & Procurement Department, Administrative Building, Lepetkata - 786006 Dibrugarh (Assam)	2500	90
---	------------------	--	------	----

Power Cable For Direct Burial Xlpe Ugac Cable (2500 meter)

Technical Specifications

[* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
GENERIC	Mode of Buying	Through bidding only	*
	Size of Cable (in Sq.mm)	50.0	50.0
	Number of cores (nos)	3.5	3.5, 4
	Cable Type	PVC outer Sheathed FR of Type ST-2 cable FR Grade C1 Category having heat resisting insulation of PVC compound type C with aluminum conductor suitable for rated voltage at 1100 volts grade and conforming to IS: 1554 Part-1 1988 reaffirmed 2005	PVC outer Sheathed FR of Type ST-2 cable FR Grade C1 Category having heat resisting insulation of PVC compound type C with aluminum conductor suitable for rated voltage at 1100 volts grade and conforming to IS: 1554 Part-1 1988 reaffirmed 2005
	BIS marked	yes	*
	BIS certificate number	-	*
	Armouring	Galvanised round steel wire armoured	Galvanised round steel wire armoured, Galvanised steel Strip armoured
	Armouring Type	single wire or strip armouring	single wire or strip armouring
	shape of conductor	Stranded	Stranded, Stranded and Shaped
CONSTRUCTIONAL	Number of armouring strip/wire for each size of cable	-	*
	size of armouring strip/wire for each size of cable	-	*
	Material of conductor	Aluminium EC Grade	*
	Weight of finished cable per meter	-	*
	In addition to marking requirements as per relevant specification, sequential marking for length, Size of the cable, Type of the cable and Drum Number shall be embossed on every metre of the cable	yes	*
	standard cable length on a drum	500 meter for cable size up to and including 185 sqmm.	*

	Part length which can be supplied by seller (meter)	-	*
	cable to be supplied on wooden drums conforming to IS: 10418/82 with latest amendments.	yes	*
	Quantity supplied shall not be more than the ordered quantity.	yes	*
CERTIFICATIONS	Availability of Type test report from Central government/NABL/ILAC accredited laboratory to prove conformity to the specification for minimum and maximum ratings.	yes	*
	Type Test Certificate No.	-	*
	Type Test Certificate date	-	*
	Name of Lab	-	*
	Address of Lab	-	*
	Test Report to be furnished to the buyer on demand	yes	*

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Dhrupad Rajkhowa	786006,M/s Brahmaputra Cracker And Polymer Limited, Contract & Procurement Department, Administrative Building, Lepetkata - 786006 Dibrugarh (Assam)	2500	90

PVC Copper Cable (Heavy Duty), TYPE: C PVC Compound , Category: 01, For Working Voltages Up T (2000 meter)

Technical Specifications

[* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
GENERIC	Governing Specification	As per IS:1554 (Part 1):1988	*
	ISI Marked	Yes	*
	BIS License Number (CM/L Number) - Must declare	-	*

	Nominal Cross Sectional Area of the Conductor (in Sq.mm)	4.0	4.0
	No. of core	4	4
	Conductor material (Complying with IS:8130:1984 latest)	Plain Copper	*
	Type of Insulation (shall conforming to IS:5831:1984 latest)	Type C PVC compound	*
	Armouring	Galvanized round steel wire armoured	Galvanized round steel wire armoured, Galvanized steel formed wire (strip) armoured
	Outer sheath (shall conforming to IS:5831:1984 latest)	Type ST 2 PVC compound	*
	Shape of Conductor	Stranded	Stranded
CONSTRUCTIONAL	Identification on cable	as per Cl. 17 of IS:1554 (Part 1):2011 latest	*
	Cable packing and marking	as per Cl. 18 of IS:1554 (Part 1):2011 latest	*
CERTIFICATIONS	Availability of Type test report from Central government/NABL/ILAC accredited laboratory to prove conformity to the specification	Yes	*
	Test report number - Must declare	-	*
	Report date - Must declare	-	*
	Name of lab - Must declare	-	*
	Address of lab - Must declare	-	*
	All the test reports and certificates shall furnish by the supplier to the buyer/consignee on demand	Yes	*

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Dhrupad Rajkhowa	786006,M/s Brahmaputra Cracker And Polymer Limited, Contract & Procurement Department, Administrative Building, Lepetkata - 786006 Dibrugarh (Assam)	2000	90

Power Cable For Direct Burial Xlpe Ugac Cable (1000 meter)

Technical Specifications

[* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
GENERIC	Mode of Buying	Through bidding only	*
	Size of Cable (in Sq.mm)	16.0	16.0
	Number of cores (nos)	4	3.5, 4
	Cable Type	PVC outer Sheathed FR of Type ST-2 cable FR Grade C1 Category having heat resisting insulation of PVC compound type C with aluminum conductor suitable for rated voltage at 1100 volts grade and conforming to IS: 1554 Part-1 1988 reaffirmed 2005	PVC outer Sheathed FR of Type ST-2 cable FR Grade C1 Category having heat resisting insulation of PVC compound type C with aluminum conductor suitable for rated voltage at 1100 volts grade and conforming to IS: 1554 Part-1 1988 reaffirmed 2005
	BIS marked	yes	*
	BIS certificate number	-	*
	Armouring	Galvanised steel Strip armoured	Galvanised steel Strip armoured
	Armouring Type	single wire or strip armouring	single wire or strip armouring
	shape of conductor	Solid	Solid, Stranded, Stranded and Shaped
CONSTRUCTIONAL	Number of armouring strip/wire for each size of cable	-	*
	size of armouring strip/wire for each size of cable	-	*
	Material of conductor	Copper	*
	Weight of finished cable per meter	-	*
	In addition to marking requirements as per relevant specification, sequential marking for length, Size of the cable, Type of the cable and Drum Number shall be embossed on every metre of the cable	yes	*
	standard cable length on a drum	1000 meter	*
	Part length which can be supplied by seller (meter)	-	*
	cable to be supplied on wooden drums conforming to IS:	yes	*

	10418/82 with latest amendments.		
	Quantity supplied shall not be more than the ordered quantity.	yes	*
CERTIFICATIONS	Availability of Type test report from Central government/NABL/ILAC accredited laboratory to prove conformity to the specification for minimum and maximum ratings.	yes	*
	Type Test Certificate No.	-	*
	Type Test Certificate date	-	*
	Name of Lab	-	*
	Address of Lab	-	*
	Test Report to be furnished to the buyer on demand	yes	*

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Dhrupad Rajkhowa	786006,M/s Brahmaputra Cracker And Polymer Limited, Contract & Procurement Department, Administrative Building, Lepetkata - 786006 Dibrugarh (Assam)	1000	90

PVC Copper Cable (Heavy Duty), TYPE: C PVC Compound , Category: 01, For Working Voltages Up T (2000 meter)

Technical Specifications

[* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
GENERIC	Governing Specification	As per IS:1554 (Part 1):1988	*
	ISI Marked	Yes	*
	BIS License Number (CM/L Number) - Must declare	-	*
	Nominal Cross Sectional Area of the Conductor (in Sq.mm)	2.5	2.5
	No. of core	4	4
	Conductor material	Plain Copper	*

	(Complying with IS:8130:1984 latest)		
	Type of Insulation (shall conforming to IS:5831:1984 latest)	Type C PVC compound	*
	Armouring	Galvanized round steel wire armoured	Galvanized round steel wire armoured, Galvanized steel formed wire (strip) armoured
	Outer sheath (shall conforming to IS:5831:1984 latest)	Type ST 2 PVC compound	*
	Shape of Conductor	Stranded	Stranded
CONSTRUCTIONAL	Identification on cable	as per Cl. 17 of IS:1554 (Part 1):2011 latest	*
	Cable packing and marking	as per Cl. 18 of IS:1554 (Part 1):2011 latest	*
CERTIFICATIONS	Availability of Type test report from Central government/NABL/ILAC accredited laboratory to prove conformity to the specification	Yes	*
	Test report number - Must declare	-	*
	Report date - Must declare	-	*
	Name of lab - Must declare	-	*
	Address of lab - Must declare	-	*
	All the test reports and certificates shall furnish by the supplier to the buyer/consignee on demand	Yes	*

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Dhrupad Rajkhowa	786006,M/s Brahmaputra Cracker And Polymer Limited, Contract & Procurement Department, Administrative Building, Lepetkata - 786006 Dibrugarh (Assam)	2000	90

Power Cable For Direct Burial Xlpe Ugac Cable (1500 meter)

Technical Specifications

[* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
GENERIC	Mode of Buying	Through bidding only	*
	Size of Cable (in Sq.mm)	10.0	10.0
	Number of cores (nos)	4	3.5, 4
	Cable Type	PVC outer Sheathed FR of Type ST-2 cable FR Grade C1 Category having heat resisting insulation of PVC compound type C with aluminum conductor suitable for rated voltage at 1100 volts grade and conforming to IS: 1554 Part-1 1988 reaffirmed 2005	PVC outer Sheathed FR of Type ST-2 cable FR Grade C1 Category having heat resisting insulation of PVC compound type C with aluminum conductor suitable for rated voltage at 1100 volts grade and conforming to IS: 1554 Part-1 1988 reaffirmed 2005
	BIS marked	yes	*
	BIS certificate number	-	*
	Armouring	Galvanised round steel wire armoured	Galvanised round steel wire armoured, Galvanised steel Strip armoured
	Armouring Type	single wire or strip armouring	single wire or strip armouring
	shape of conductor	Stranded and Shaped	Stranded, Stranded and Shaped
CONSTRUCTIONAL	Number of armouring strip/wire for each size of cable	-	*
	size of armouring strip/wire for each size of cable	-	*
	Material of conductor	Aluminium EC Grade	*
	Weight of finished cable per meter	-	*
	In addition to marking requirements as per relevant specification, sequential marking for length, Size of the cable, Type of the cable and Drum Number shall be embossed on every metre of the cable	yes	*
	standard cable length on a drum	500 meter for cable size up to and including 185 sqmm.	*
	Part length which can be supplied by seller (meter)	-	*
	cable to be supplied on wooden drums conforming to IS: 10418/82 with latest amendments.	yes	*
	Quantity supplied shall not be more than the ordered quantity.	yes	*

CERTIFICATIONS	Availability of Type test report from Central government/NABL/ILAC accredited laboratory to prove conformity to the specification for minimum and maximum ratings.	yes	*
	Type Test Certificate No.	-	*
	Type Test Certificate date	-	*
	Name of Lab	-	*
	Address of Lab	-	*
	Test Report to be furnished to the buyer on demand	yes	*

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Dhrupad Rajkhowa	786006,M/s Brahmaputra Cracker And Polymer Limited, Contract & Procurement Department, Administrative Building, Lepetkata - 786006 Dibrugarh (Assam)	1500	90

Power Cable For Direct Burial Xlpe Ugac Cable (1000 meter)

Technical Specifications

[* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
GENERIC	Mode of Buying	Through bidding only	*
	Size of Cable (in Sq.mm)	2.5	2.5
	Number of cores (nos)	3	3
	Cable Type	Cross linked polyethylene and XLPE Insulated PVC Outer sheathed Cable with copper conductor suitable for rated voltage at 1100 Volts Grade and confirming to IS 7098 Part-1 1988 with amendment No.1 ,2 & 3 reaffirmed in 2005	PVC outer Sheathed FR of Type ST-2 cable FR Grade C1 Category having heat resisting insulation of PVC compound type C with aluminum conductor suitable for rated voltage at 1100 volts grade and conforming to IS: 1554 Part-1 1988 reaffirmed 2005, Cross linked polyethylene and XLPE Insulated PVC Outer sheathed Cable with copper

			conductor suitable for rated voltage at 1100 Volts Grade and confirming to IS 7098 Part-1 1988 with amendment No.1 ,2 & 3 reaffirmed in 2005
	BIS marked	yes	*
	BIS certificate number	-	*
	Armouring	Galvanised round steel wire armoured	Galvanised round steel wire armoured, Galvanised steel Strip armoured
	Armouring Type	single wire or strip armouring	single wire or strip armouring
	shape of conductor	Stranded	Stranded, Stranded and Shaped
CONSTRUCTIONAL	Number of armouring strip/wire for each size of cable	-	*
	size of armouring strip/wire for each size of cable	-	*
	Material of conductor	Copper	*
	Weight of finished cable per meter	-	*
	In addition to marking requirements as per relevant specification, sequential marking for length, Size of the cable, Type of the cable and Drum Number shall be embossed on every metre of the cable	yes	*
	standard cable length on a drum	1000 meter	*
	Part length which can be supplied by seller (meter)	-	*
	cable to be supplied on wooden drums conforming to IS: 10418/82 with latest amendments.	yes	*
	Quantity supplied shall not be more than the ordered quantity.	yes	*
CERTIFICATIONS	Availability of Type test report from Central government/NABL/ILAC accredited laboratory to prove conformity to the specification for minimum and maximum ratings.	yes	*
	Type Test Certificate No.	-	*
	Type Test Certificate date	-	*

Name of Lab	-	*
Address of Lab	-	*
Test Report to be furnished to the buyer on demand	yes	*

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Dhrupad Rajkhowa	786006,M/s Brahmaputra Cracker And Polymer Limited, Contract & Procurement Department, Administrative Building, Lepetkata - 786006 Dibrugarh (Assam)	1000	90

PVC Copper Cable (Heavy Duty), TYPE: C PVC Compound , Category: 01, For Working Voltages Up T (1000 meter)

Technical Specifications

[* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
GENERIC	Governing Specification	As per IS:1554 (Part 1):1988	*
	ISI Marked	Yes	*
	BIS License Number (CM/L Number) - Must declare	-	*
	Nominal Cross Sectional Area of the Conductor (in Sq.mm)	6.0	6.0
	No. of core	3	3
	Conductor material (Complying with IS:8130:1984 latest)	Plain Copper	*
	Type of Insulation (shall conforming to IS:5831:1984 latest)	Type C PVC compound	*
	Armouring	Galvanized round steel wire armoured	Galvanized round steel wire armoured, Galvanized steel formed wire (strip) armoured
	Outer sheath (shall conforming to IS:5831:1984 latest)	Type ST 2 PVC compound	*
	Shape of Conductor	Stranded	Stranded
CONSTRUCTIONAL	Identification on cable	as per Cl. 17 of IS:1554 (Part 1):2011 latest	*

	Cable packing and marking	as per Cl. 18 of IS:1554 (Part 1):2011 latest	*
CERTIFICATIONS	Availability of Type test report from Central government/NABL/ILAC accredited laboratory to prove conformity to the specification	Yes	*
	Test report number - Must declare	-	*
	Report date - Must declare	-	*
	Name of lab - Must declare	-	*
	Address of lab - Must declare	-	*
	All the test reports and certificates shall furnish by the supplier to the buyer/consignee on demand	Yes	*

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Dhrupad Rajkhowa	786006,M/s Brahmaputra Cracker And Polymer Limited, Contract & Procurement Department, Administrative Building, Lepetkata - 786006 Dibrugarh (Assam)	1000	90

Power Cable For Direct Burial Xlpe Ugac Cable (2000 meter)

Technical Specifications

[* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
GENERIC	Mode of Buying	Through bidding only	*
	Size of Cable (in Sq.mm)	16.0	16.0
	Number of cores (nos)	3	3
	Cable Type	PVC outer Sheathed FR of Type ST-2 cable FR Grade C1 Category having heat resisting insulation of PVC compound type C with aluminum conductor suitable for rated voltage at 1100 volts grade and	PVC outer Sheathed FR of Type ST-2 cable FR Grade C1 Category having heat resisting insulation of PVC compound type C with aluminum conductor suitable for rated voltage at 1100 volts grade and

		conforming to IS: 1554 Part-1 1988 reaffirmed 2005	conforming to IS: 1554 Part-1 1988 reaffirmed 2005
	BIS marked	yes	*
	BIS certificate number	-	*
	Armouring	Galvanised steel Strip armoured	Galvanised steel Strip armoured
	Armouring Type	single wire or strip armouring	single wire or strip armouring
	shape of conductor	Solid	Solid, Stranded and Shaped
CONSTRUCTIONAL	Number of armouring strip/wire for each size of cable	-	*
	size of armouring strip/wire for each size of cable	-	*
	Material of conductor	Copper	*
	Weight of finished cable per meter	-	*
	In addition to marking requirements as per relevant specification, sequential marking for length, Size of the cable, Type of the cable and Drum Number shall be embossed on every metre of the cable	yes	*
	standard cable length on a drum	1000 meter	*
	Part length which can be supplied by seller (meter)	-	*
	cable to be supplied on wooden drums conforming to IS: 10418/82 with latest amendments.	yes	*
CERTIFICATIONS	Quantity supplied shall not be more than the ordered quantity.	yes	*
	Availability of Type test report from Central government/NABL/ILAC accredited laboratory to prove conformity to the specification for minimum and maximum ratings.	yes	*
	Type Test Certificate No.	-	*
	Type Test Certificate date	-	*
	Name of Lab	-	*
	Address of Lab	-	*
	Test Report to be furnished to the buyer on demand	yes	*

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Dhrupad Rajkhowa	786006,M/s Brahmaputra Cracker And Polymer Limited, Contract & Procurement Department, Administrative Building, Lepetkata - 786006 Dibrugarh (Assam)	2000	90

Special terms and conditions for category power cable for direct burial xlpe ugac cable

- 1.Specification for Cross linked Polyethylene insulated thermoplastic sheathed cables" is as per IS:7098 (Part 1):1988 with latest amendments including amendment no.5. Manufacturer shall furnish calculation sheet as per Appendix-C of IS:7098 (Part 1):1988 amdt., no.5 to buyer/consignee on demand. (Gem Category: Cross linked polyethylene and XLPE insulated PVC outer sheathed cable with aluminum conductor suitable for rated voltage at 1100 volts grade and conforming to IS: 7098 Part-1 1988 with latest amendment including amendment no.5)

Bid Specific Additional Terms and Conditions

- 1.Scope of supply (Bid price to include all cost components) : Only supply of Goods
- 2.Experience Criteria: The Bidder or its OEM {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU / Public Listed Company for 2 years before the bid opening date. Copies of relevant contracts to be submitted along with bid in support of having supplied some quantity during each of the year. In case of bunch bids, the primary product having highest value should meet this criterion.
- 3.**Upload Manufacturer authorization:** Wherever Authorised Distributors are submitting the bid, Manufacturers Authorisation Form (MAF)/Certificate with OEM details such as name, designation, address, e-mail Id and Phone No. required to be furnished along with the bid.
- 4.Bidders are advised to check applicable GST on their own before quoting. Buyer will not take any responsibility in this regards. GST reimbursement will be as per actuals or as per applicable rates (whichever is lower), subject to the maximum of quoted GST %.
- 5.Data Sheet of the product(s) offered in the bid, are to be uploaded along with the bid documents. Buyers can match and verify the Data Sheet with the product specifications offered. In case of any unexplained mismatch of technical parameters, the bid is liable for rejection.
- 6.Supplier shall ensure that the Invoice is raised in the name of Consignee with GSTIN of Consignee only.
- 7.Bidder Turn Over Criteria: The minimum average annual financial turnover of the bidder during the last three years, ending on 31st March of the previous financial year, should be as indicated in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the bidder is less than 3 year old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.
- 8.**Pre-dispatch inspection at Seller premises (Fee/Charges to be borne by the BUYER):** Before dispatch, the goods will be inspected by Buyer / Consignee or their Authorized Representative or by Nominated External Inspection Agency (independently or jointly with Buyer or Consignee as decided by the Buyer) at Seller premises (or at designated place for inspection as declared / communicated by the seller) for their compliance to the contract specifications. Fee/Charges taken by the External inspection Agency and any external laboratories testing charges shall be borne by the Buyer. For in-house testing, the Sellers will provide necessary facilities free of cost. Seller shall notify the Buyer through e-mail about readiness of goods for pre-dispatch inspection and Buyer will notify the Seller about the Authorized Representative/ Nominated External Inspection Agency and the date for testing. The goods would be dispatched to consignee only after clearance in pre-dispatch inspection. Consignee's right of rejection as per GTC in respect of the goods finally received at his location shall in no way be limited or waived by reason of the goods having previously been inspected, tested and passed by Buyer/ Consignee or its Nominated External Inspection Agency prior to the goods' shipment. While bidding, the sellers should take into account 7 days for inspection from the date of email offering the goods for inspection. Any delay in inspection beyond 7 days shall be on the part of the buyer and shall be regularised without Liquidated Damages.
When there is requirement of submission the advance sample, the seller shall inform the buyer promptly through emails about the date of submission of sample to the buyer nominated Inspection agency.

9. Warranty period of the supplied products shall be 1 years from the date of final acceptance of goods or after completion of installation, commissioning & testing of goods (if included in the scope of supply), at consignee location. OEM Warranty certificates must be submitted by Successful Bidder at the time of delivery of Goods. The seller should guarantee the rectification of goods in case of any break down during the guarantee period. Seller should have well established Installation, Commissioning, Training, Troubleshooting and Maintenance Service group in INDIA for attending the after sales service. Details of Service Centres near consignee destinations are to be uploaded along with the bid
10. Timely Servicing / rectification of defects during warranty period: After having been notified of the defects / service requirement during warranty period, Seller has to complete the required Service / Rectification within 15 days time limit. If the Seller fails to complete service / rectification with defined time limit, a penalty of 0.5% of Unit Price of the product shall be charged as penalty for each week of delay from the seller. Seller can deposit the penalty with the Buyer directly else the Buyer shall have a right to recover all such penalty amount from the Performance Security (PBG). Cumulative Penalty cannot exceed more than 10% of the total contract value after which the Buyer shall have the right to get the service / rectification done from alternate sources at the risk and cost of the Seller besides forfeiture of PBG. Seller shall be liable to re-imburse the cost of such service / rectification to the Buyer.
11. Bidder's offer is liable to be rejected if they don't upload any of the certificates / documents sought in the Bid document, ATC and Corrigendum if any.
12. The bidder is required to upload, along with the bid, all relevant certificates such as BIS licence, type test certificate, approval certificates and other certificates as prescribed in the Product Specification given in the bid document.
13. Purchase preference to Micro and Small Enterprises (MSEs): Purchase preference will be given to MSEs as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail the Purchase preference, the bidder must be the manufacturer of the offered product in case of bid for supply of goods. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service. If L-1 is not an MSE and MSE Seller (s) has/have quoted price within L-1+ 15% of margin of purchase preference /price band defined in relevant policy, such Seller shall be given opportunity to match L-1 price and contract will be awarded for percentage of 25% of total value.
14. Bidders can also submit the EMD with Account Payee Demand Draft in favour of Brahmaputra Cracker and Polymer Limited payable at Dibrugarh. Bidder has to upload scanned copy / proof of the DD along with bid and has to ensure delivery of hardcopy to the Buyer within 5 days of Bid End date / Bid Opening date.
15. Successful Bidder can submit the Performance Security in the form of Account Payee Demand Draft also (besides PBG which is allowed as per GeM GTC). DD should be made in favour of Brahmaputra Cracker and Polymer Limited payable at Dibrugarh. After award of contract, Successful Bidder can upload scanned copy of the DD in place of PBG and has to ensure delivery of hard copy to the original DD to the Buyer within 15 days of award of contract.
16. For fulfilling the experience criteria any one of the following documents may be considered as valid proof for meeting the experience criteria:
 - a. Purchase Order copy along with Invoice(s) with self-certification by the bidder that supplies against the invoices have been executed.
 - b. Execution certificate by client with order value.
 - c. Any other document in support of order execution like Third Party Inspection release note, etc.
17. To be eligible for award of contract, Bidder / OEM must possess following Certificates / Test Reports on the date of bid opening (to be uploaded with bid): type test certificate of offered items or type test certificate of the higher rating item along with an undertaking for providing type test certificates of each and every types of cable..

[This Bid is also governed by the General Terms and Conditions](#)

In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

---Thank You---