

FIRE & SAFETY DEPARTMENT, BCPL
CO2 EXTINGUISHER MAINTENCE FORMAT

Type of maintenace : Quaterly

MONTH: November

CAPACITY - 4.5 KGS

CAPACITY - 4.5 KGS

SN	Area	ID	LOCATION		DATE	NET WEIGHT OF CO2		DATE	NET WEIGHT OF CO2		DISCHARGE		VALVE WHEEL	SAFETY PIN	REMARKS
						Empty	Net weight		Empty	Net weight	HOSE	HORN			
					Nov	Dec-14		Dec	Jan15						
1	Sub station 06	C-4.5-101	First floorSouth side wall		02/12/2014	11.60	16.2	02/01/15	11.60	16.2	OK	OK	OK	Available	OK
2	Sub station 06	C-4.5-098	First floorSouth side wall		02/12/2014	10.90	15.2	02/01/15	10.90	15.2	OK	OK	OK	Available	OK
3	Sub station 06	C-4.5-097	First floorSouth side wall		02/12/2014	11.00	15.4	02/01/15	11.00	15.4	OK	OK	OK	Available	OK
4	Sub station 06	C-4.5-099	First floor East side wall		02/12/2014	10.90	15.5	02/01/15	10.90	15.5	OK	OK	OK	Available	OK
5	Sub station 06	C-4.5-072	First floor north side wall		02/12/2014	11.70	16.2	02/01/15	11.70	16.2	OK	OK	OK	Available	OK
6	Sub Station 04	C-4.5-102	First floor South side wall		02/12/2014	11.00	15.2	03/01/15	11.00	15.2	OK	OK	OK	Available	OK
7	Sub Station 04	C-4.5-039	First floor south side wall		02/12/2014	11.10	15	03/01/15	11.10	15	OK	OK	OK	Available	OK
8	Sub Station 04	C-4.5-077	First floor east side wall		02/12/2014	11.00	15.2	03/01/15	11.00	15.2	OK	OK	OK	Available	OK
9	Sub Station 04	C-4.5-009	First floor east side wall		02/12/2014	11.00	15.6	03/01/15	11.00	15.6	OK	OK	OK	Available	OK
10	Sub Station 04	C-4.5-078	First floor north side wall		02/12/2014	11.30	15.5	03/01/15	11.30	15.5	OK	OK	OK	Available	OK
11	Sub Station 04	C-4.5-084	East side wall		02/12/2014	11.10	15.7	03/01/15	11.10	15.7	OK	OK	OK	Available	OK
12	Sub Station 04	C-4.5-076	North side wall		02/12/2014	11.10	15.5	03/01/15	11.10	15.5	OK	OK	OK	Available	OK
13	Sub Station 04	C-4.5-038	West side wall		02/12/2014	11.20	15.6	03/01/15	11.20	15.6	OK	OK	OK	Available	OK
14	Sub Station 02	C-4.5-091	Ground floor corridor		02/12/2014	11.10	15.5	02/01/15	11.10	15.5	OK	OK	OK	Available	OK
15	Sub Station 02	C-4.5-075	Ground floor corridor		02/12/2014	10.9	15.3	02/01/15	10.9	15.3	OK	OK	OK	Available	OK
16	Sub Station 02	C-4.5-086	First floor east side wall		02/12/2014	11.2	15.5	02/01/15	11.2	15.5	OK	OK	OK	Available	OK
17	Sub Station 02	C-4.5-090	First floor north side wall		02/12/2014	11.10	15.6	02/01/15	11.10	15.6	OK	OK	OK	Available	OK
18	Sub Station 02	C-4.5 - 74	First floor east side wall		02/12/2014	11.00	15.3	02/01/15	11.00	15.3	OK	OK	OK	Available	OK
19	Sub Station 02	C-4.5-092	First floor south side wall		02/12/2014	11.40	15.9	02/01/15	11.40	15.9	OK	OK	OK	Available	OK
20	Sub Station 02	C-4.5-089	First floor south side wall		02/12/2014	11.10	15.3	02/01/15	11.10	15.3	OK	OK	OK	Available	OK
21	Sub Station 02	C-4.5-095	First floor South side wall		02/12/2014	11.00	15.2	02/01/15	11.00	15.2	OK	OK	OK	Available	OK
22	Sub Station 9A	C-4.5-002	Ground floor west side of the wall		02/12/2014	11.00	15.3	26/12/14	11.00	15.3	OK	OK	OK	Available	OK
23	Sub Station 9A	C-4.5-035	Ground floor corridor SS 9A TY40		02/12/2014	11.00	15.3	26/12/14	11.00	15.3	OK	OK	OK	Available	OK
24	Sub Station 9A	C-4.5-004	First floor west side wall		02/12/2014	11.10	15.5	26/12/14	11.10	15.5	OK	OK	OK	Available	OK
25	Sub Station 9A	C-4.5-036	First floor north side wall		02/12/2014	11.3	15.6	26/12/14	11.3	15.6	OK	OK	OK	Available	OK
26	Sub Station 9A	C-4.5-008	First floor west side wall		02/12/2014	10.9	15.5	26/12/14	10.9	15.5	OK	OK	OK	Available	OK
27	Sub Station 9A	C-4.5-037	First floor West side wall		02/12/2014	11.2	15.5	26/12/14	11.2	15.5	OK	OK	OK	Available	OK

28	Sub Station 9A	C-4.5-007	First floor east side wall		02/12/2014	11.00	15.3	26/12/14	11.00	15.3	OK	OK	OK	Available	OK
29	Sub Station 11	C-4.5-031	Ground floor corridor		02/12/2014	11.10	14	26/12/14(Replaced)	11.10	15.7	OK	OK	OK	Available	To be replaced
30	Sub Station 11	C-4.5-032	Ground floor north side		02/12/2014	11.30	14.3	26/12/14(Replaced)	11.20	15.8	OK	OK	OK	Available	To be replaced
31	Sub Station 11	C-4.5-033	First floor west side wall		02/12/2014	11.00	14.8	26/12/14(Replaced)	10.9	15.5	OK	OK	OK	Available	To be replaced
32	Sub Station 11	C-4.5-34	First floor north side wall		02/12/2014	11.00	15.3	26/12/14	11.00	15.3	OK	OK	OK	Available	OK
33	Sub Station 11	C-4.5-001	First floor south side wall		02/12/2014	11.10	15.5	26/12/14	11.10	15.5	OK	OK	OK	Available	OK
34	Sub Station 01	C-4.5-109	First floor east side wall		02/12/2014	1200	16.5	26/12/14	1200	16.5	OK	OK	OK	Available	OK
35	Sub Station 01	C-4.5-108	First floor east side wall		02/12/2014	10.9	15.3	26/12/14	10.9	15.3	OK	OK	OK	Available	OK
36	Sub Station 01	C-4.5-107	East side wall First floor		02/12/2014	11.10	15.5	26/12/14	11.10	15.5	OK	OK	OK	Available	OK
37	Sub Station 01	C-4.5-106	First floor North side wall		02/12/2014	11.40	15.3	26/12/14	11.40	15.3	OK	OK	OK	Available	OK
38	Sub Station 01	C-4.5-112	First floor west side wall		02/12/2014	11.3	15.8	26/12/14	11.3	15.8	OK	OK	OK	Available	OK
39	Sub Station 01	C-4.5-111	First floor west side wall		02/12/2014	11	15.3	26/12/14	11	15.3	OK	OK	OK	Available	OK
40	Sub Station 01	C-4.5-113	First floor east side wall		02/12/2014	10.8	15.3	26/12/14	10.8	15.3	OK	OK	OK	Available	OK
41	Sub Station 01	C-4.5-114	First floor east side wall		02/12/2014	10.9	15.4	26/12/14	10.9	15.4	OK	OK	OK	Available	OK
42	Sub Station 01	C-4.5-115	First floor east side wall		02/12/2014	11.00	15	26/12/14	11.00	15	OK	OK	OK	Available	OK
43	Admin Building	C-4.5-021	First floor MD Room		02/12/2014	11.10	15.5	26/12/14	11.10	15.5	OK	OK	OK	Available	OK
44	Admin Building	C-4.5-024	First floor near IT dept.		02/12/2014	11.45	15.5	26/12/14	11.45	15.5	OK	OK	OK	Available	OK
45	Sub Station 14	C-4.5-085	East side wall		02/12/2014	11.00	15.5	26/12/14	11.00	15.5	OK	OK	OK	Available	OK
46	GSU	C-4.5-096	North west corner		03/12/2014	11.80	16.23	31/12/14	11.80	16.2	OK	OK	OK	Available	OK
47	GSU	C-4.5-010	Feed gas compressor		03/12/2014	11.20	15.8	31/12/14	11.20	15.8	OK	OK	OK	Available	OK
48	GSU	C-4.5-057	West side separator-2		03/12/2014	11.00	15.6	31/12/14	11.00	15.6	OK	OK	OK	Available	OK
49	GSU	C-4.5-048	East side		03/12/2014	11	15.6	31/12/14	11	15.6	OK	OK	OK	Available	OK
10	GSU	C-4.5-061	Ground Floor Compressor House		03/12/2014	11.1	15.8	31/12/14	11.1	15.8	OK	OK	OK	Available	OK
11	Sub station 12	C-4.5-030	First floor South side wall		03/12/2014	11.4	15.5	27/12/14	11.4	15.5					
12	Sub station 12	C-4.5-026	First floor North side wall		03/12/2014	11.3	15.5	27/12/14	11.3	15.5					
13	Sub station 12	C-4.5-027	First floor West side wall		03/12/2014	11.0	15	27/12/14	11.0	15					
14	Sub station 12	C-4.5-029	Ground floor TY 36		03/12/2014	11.0	15	27/12/14	11.0	15					
15	Sub station 12	C-4.5-024	Ground floor		03/12/2014	11.0	15.2	27/12/14	11.0	15.2					
16	Sub station 07	C-4.5-126	Ground floor South side wall		03/12/2014	11.5	16	27/12/14	11.5	16					
17	Sub station 07	C-4.5-129	Ground floor North side wall		03/12/2014	11.1	15.5	27/12/14	11.1	15.5					
18	Sub station 07	C-4.5-125	First floor West side wall		03/12/2014	11.2	15.5	27/12/14	11.2	15.5					
19	Sub station 07	C-4.5-127	First floor North side wall		03/12/2014	11.80	16	27/12/14	11.80	16					
20	Sub station 07	C-4.5-128	First floor East side wall		03/12/2014	10.9	15.5	27/12/14	10.9	15.5					
21	Sub station 09	C-4.5-047	West side wall of control room		03/12/2014	11	15.5	27/12/14	11	15.5					
22	Sub station 09	C-4.5-055	First floor East side wall		03/12/2014	11.3	15.5	27/12/14	11.3	15.5					
23	Sub station 09	C-4.5-043	First floor East side wall		03/12/2014	11.1	15	27/12/14	11.1	15					
24	Sub station 09	C-4.5-044	First floor West side wall		03/12/2014	11.2	15.5	27/12/14	11.2	15.5					

25	Sub station 09	C-4.5-042	First floor South side wall		03/12/2014	11.9	16	27/12/14	11.9	16					
26	Sub station 09	C-4.5-049	Ground floor South side wall		03/12/2014	11	15.5	27/12/14	11	15.5					
27	Sub station 09	C-4.5-045	Ground floor TY 34		03/12/2014	10.9	15	27/12/14	10.9	15					
28	DG Room ECU	C-4.5-087	South side wall					31/12/14	10.9	15.4					
29	DG Room ECU	C-4.5-002	East Side Wall					31/12/14	11.5	15.4					
30	DG Room ECU	C-4.5-093	Engine Room North side wall					31/12/14	11	15.5					
31	DG Room ECU	C-4.5-061	Engine Room West side wall					31/12/14	11.49	16					
31	Sub station 03	C-4.5-059	First floor East side wall		03/12/2014	11.5	16	02/1/15	11.5	16					
32	Sub station 03	C-4.5-016	First floor North side wall		03/12/2014	11.2	15.8	02/1/15	11.2	15.8					
33	Sub station 03	C-4.5-060	First floor South side wall		03/12/2014	11.2	15.7	02/1/15	11.2	15.7					
34	Sub station 03	C-4.5-017	First floor South side wall		03/12/2014	11	15.4	02/1/15	11	15.4					
35	Sub station 03	C-4.5-028	First floor West side wall		03/12/2014	10.8	15.5	02/1/15	10.8	15.5					
36	Sub station 05	C-4.5-056	East Side Wall		03/12/2014	11	15.8	02/1/15	11	15.8					
37	Sub station 05	C-4.5-019	East Side Wall		03/12/2014	10.9	15.4	02/1/15	10.9	15.4					
38	Sub station 05	C-4.5-020	West side wall		03/12/2014	10.9	15.4	02/1/15	10.9	15.4					
39	Sub station 05	C-4.5-054	West side wall		03/12/2014	10.9	15.5	02/1/15	10.9	15.5					
40	Lab Building	C-4.5-013	Ground Floor Corridor		02/12/2014			31/12/14							
41	CSS#01	C-4.5-027	South side wall		03/12/2014	12.1	16.5	03/1/15	12.1	16.5					
42	CSS#01	C-09-004	Ground Floor		03/12/2014	21	30	03/1/15	21	30					
43	CSS#02	C-4.5-026	East Side Wall		03/12/2014	11.28	16	03/1/15	11.28	16					
44	CSS#02	C-09-003	Ground Floor		03/12/2014	20.8	30	03/1/15	20.8	30					
45	CSS#03	C-4.5-028	East Side Wall		03/12/2014	11.1	15.6	03/1/15	11.1	15.6					
46	CSS#03	C-09-005	Ground Floor		03/12/2014	21	30	03/1/15	21	30					
47	CSS#04	C-4.5-029	West side wall		03/12/2014	11.3	15.7	03/1/15	11.3	15.7					
48	CSS#04	C-09-006	Ground Floor		03/12/2014	21	30	03/1/15	21	30					
1	CSS#05	C-4.5-030	North side wall		03/12/2014	11.5	16	03/1/15	11.5	16					
2	CSS#05	C-09-007	Ground Floor		03/12/2014	21	30	03/1/15	21	30					
3	CSS#06	C-4.5-031	North side wall		03/12/2014	11.1	15.8	03/1/15	11.1	15.8					
4	CSS#06	C-09-008	Ground Floor		03/12/2014	21	30	03/1/15	21	30					
5	CSS#07	C-4.5-025	East Side Wall		03/12/2014	10.7	15.4	03/1/15	10.7	15.4					
6	CSS#07	C-4.5-024	West side wall		03/12/2014	10.2	14.7	03/1/15	10.2	14.7					
7	MRSS	C-09-001	Ground Floor		03/12/2014	21.1	30	03/1/15	21.1	30					
8	MRSS	C-4.5-023	North side wall		03/12/2014	11.3	15.8	03/1/15	11.3	15.8					
9	Multipurpose Tender 01	C-4.5-MP-01	Multipurpose Tender 01					03/1/15	11.5	16					
10	Multipurpose Tender 01	C-4.5-MP-02	Multipurpose Tender 01					03/1/15	11	15.5					
11	Multipurpose Tender 02	C-4.5-005						03/1/15	11	15.5					